

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140116-E254912  
**Report Reference** E254912-20061006  
**Issue Date** 2014-JANUARY-16

**Issued to:** MJK AUTOMATION APS  
Byageren 7  
2850 Naerum DENMARK

**This is to certify that  
representative samples of**


TELEMETERING EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS  
See addendum page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** Intrinsically Safe Apparatus and Associated Apparatus for  
Use in Class I, II, and III, Division 1, Hazardous (Classified)  
Locations, UL 913

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140116-E254912  
**Report Reference** E254912-20061006  
**Issue Date** 2014-JANUARY-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model 1400 or 3400 Hydrostatic Level Transmitter (Telemetry Equipment for Use in Hazardous Locations ) provides nonincendive field circuits for use in Class I, Division 1, Groups A, B, C & D Hazardous Locations when installed in accordance with manufacturer's control drawing no. 5222.

|                   |                   |                   |
|-------------------|-------------------|-------------------|
| 203909 Model 1400 | 209909 Model 3400 | range 0 – 3 bar   |
| 203910 Model 1400 | 209910 Model 3400 | range 0 – 10 bar  |
| 203911 Model 1400 |                   | range 0 – 0,3 mWG |
| 203912 Model 1400 |                   | range 0 – 1 mWG   |
| 203913 Model 1400 |                   | range 0 – 3 mWG   |
| 203914 Model 1400 |                   | range 0 – 5 mWG   |
| 203915 Model 1400 |                   | range 0 – 10 mWG  |
| 203916 Model 1400 |                   | range 0 – 30 mWG  |
| 203917 Model 1400 |                   | range 0 – 100 mWG |
| 203918 Model 1400 |                   | range 0 – 300 mWG |

|                   |                   |                                  |
|-------------------|-------------------|----------------------------------|
| 209911 Model 1400 | 209921 Model 3400 | range 0 – 1 ft, 39 ft Cable      |
| 209912 Model 1400 | 209922 Model 3400 | range 0 – 3 ft, 39 ft Cable      |
| 209913 Model 1400 | 209923 Model 3400 | range 0 – 10 ft, 39 ft Cable     |
| 209914 Model 1400 | -                 | range 0 – 15 ft, 39 ft Cable     |
| 209915 Model 1400 | 209925 Model 3400 | range 0 – 30 ft, 39 ft Cable     |
| 209916 Model 1400 | 209926 Model 3400 | range 0 – 100 ft, 105 ft Cable   |
| 209917 Model 1400 | 209927 Model 3400 | range 0 – 300 ft, 330 ft Cable   |
| 209918 Model 1400 | 209928 Model 3400 | range 0 – 1000 ft, 1030 ft Cable |



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

